



**SECTION A-A**

**NOTES:**

1. WHEN CONSTRUCTION IS WITHIN FDOT JURISDICTION, ADDITIONAL REQUIREMENTS OF THE UTILITY ACCOMMODATION GUIDE SHALL BE MET.
2. WHERE PRACTICAL, CASING SHALL EXTEND 10' BEYOND EDGE OF PAVEMENT AND SHALL NOT BE LESS THAN 6' BEYOND EDGE OF PAVEMENT IN ANY CASE. THE CITY MAY REQUIRE LONGER CASING FOR DEEPER BORES.
3. CASING PIPE JOINTS SHALL BE MADE BY USING A FULL CIRCUMFERENCE COMPLETE PENETRATION GROOVE WELD.

	CARRIER & CASING SIZE									
CARRIER	4"	6"	8"	10"	12"	14"	16"	18"	20"	24"
CASING	12"	14"	16"	18"	20"	24"	30"	30"	30"	36"
CASING / WALL THICKNESS	0.250"	0.250"	0.250"	0.250"	0.250"	0.250"	0.312"	0.312"	0.312"	0.375"

**JACK & BORE UNDER PAVED ROADS**  
NOT TO SCALE

REV	DATE	BY	REVISIONS
1	20 JAN 11	REFJHS	REV. SHT. NO. TO ADD DIR. BORE DETAIL



**TECHNICAL  
STANDARDS  
MANUAL**

**JACK & BORE UNDER  
PAVED ROADS  
TECHNICAL STANDARDS MANUAL**  
CITY OF LYNN HAVEN FLORIDA

CAD FILE:	SEWER
DWN BY:	REF
DATE:	30 APR 07
SHEET NO:	17 OF 20
DETAIL	S-17