



ALL POLYETHYLENE PIPING SHALL MEET CITY OF LYNN HAVEN STANDARDS AND SPECIFICATIONS

SDR-9, CLASS 200 FOR POTABLE WATER & RECLAIMED WATER
 SDR-11, CLASS 160 FOR SANITARY FORCE MAINS
 COLOR CODED BLUE FOR POTABLE WATER
 COLOR CODED PURPLE FOR RECLAIMED WATER
 COLOR CODED GREEN FOR SANITARY FORCE MAIN

PIPE DIAMETER "D" IN INCHES	MIN. RADIUS FOR SDR-11 FOR SDR-11	MIN. RADIUS "R" FOR SDR-9	MIN. RADIUS "R" FOR SDR-9
2	4	5.5	
3	6	8.3	
4	8	11.0	
6	12	16.5	
8	16	22.0	
10	20	27.5	
12	24	33.0	
16	32	44.0	
18	36	49.5	
20	40	55.0	

DIRECTIONAL BORE CANAL CROSSING
 NOT TO SCALE

© CITY OF LYNN HAVEN ALL RIGHTS RESERVED. NO PART OF THIS DOCUMENT MAY BE REPRODUCED OR UTILIZED IN ANY FORM WITHOUT PRIOR WRITTEN AUTHORIZATION OF THE CITY OF LYNN HAVEN



TECHNICAL STANDARDS MANUAL

DIRECTIONAL BORE CANAL CROSSING
 TECHNICAL STANDARDS MANUAL
 CITY OF LYNN HAVEN FLORIDA

CAD FILE:	DBCC
DWN BY:	JEH
DATE:	30 APR 07
SHEET NO:	15 OF 19
DETAIL:	S-15