



NOTES:

1. WHEN CONSTRUCTION IS WITHIN FDOT JURISDICTION, ADDITIONAL REQUIREMENTS OF THE UTILITY ACCOMMODATION GUIDE SHALL BE MET.
2. WHERE PRACTICAL, CASING SHALL EXTEND 10' BEYOND EDGE OF PAVEMENT AND SHALL NOT BE LESS THAN 6' BEYOND EDGE OF PAVEMENT IN ANY CASE. THE CITY MAY REQUIRE LONGER CASING FOR DEEPER BORES.
3. CASING PIPE JOINTS SHALL BE MADE BY USING A FULL CIRCUMFERENCE COMPLETE PENETRATION GROOVE WELD.

CARRIER & CASING SIZE										
CARRIER	4"	6"	8"	10"	12"	14"	16"	18"	20"	24"
CASING	12"	14"	16"	18"	20"	24"	30"	30"	30"	36"
CASING / WALL THICKNESS	0.250"	0.250"	0.250"	0.250"	0.250"	0.250"	0.312"	0.312"	0.312"	0.375"

# JACK & BORE UNDER PAVED ROADS

NOT TO SCALE

© CITY OF LYNN HAVEN ALL RIGHTS RESERVED. NO PART OF THIS DOCUMENT MAY BE REPRODUCED OR UTILIZED IN ANY FORM WITHOUT PRIOR WRITTEN AUTHORIZATION OF THE CITY OF LYNN HAVEN

Date: Apr 30, 2007, 2:25pm User ID: JEHFile: P:\14340 Comp Plan\Drawings\REVIEWS\TWO\SEWER.dwg



**TECHNICAL  
STANDARDS  
MANUAL**

**JACK & BORE UNDER  
PAVED ROADS  
TECHNICAL STANDARDS MANUAL**  
CITY OF LYNN HAVEN FLORIDA

CAD FILE:	J&BUPR
DWN BY:	JEH
DATE:	30 APR 07
SHEET NO:	16 OF 19
DETAIL	S-16