

DIRECTIONAL BORE NOTES

- 1.) DIRECTION BORES FOR FORCE/WATER MAINS SHALL USE HDPE DR11/DR9 W/AWWA DIP SIZE & GREEN/BLUE STRIPE. FOR HDPE CONNECTIONS TO AWWA C900 OR DIP, USE HDPE MJ ADAPTER KIT (INDEPENDENT PIPE PRODUCTS OR APPROVED EQUAL). PROVIDE RESTRAINTS THREE (3) PIPE JOINTS BEYOND HDPE & PVC/DIP ADAPTER.
- 2.) PROVIDE CITY WITH "FRAC OUT PLAN" FOR REVIEW/APPROVAL ONE WEEK (MIN.) PRIOR TO SCHEDULING WORK.
- 3.) (REFER TO GENERAL NOTES FOR MORE INFO.)

REV	DATE	BY	REVISIONS
2	13 DEC 11	REF JHS	REVISED NOTES
1	03 JUN 11	REF	REV. SHT. NO. TO ADD DIR. BORE DETAIL



DIRECTIONAL BORE
NOTES

TECHNICAL STANDARDS MANUAL

CITY OF LYNN HAVEN FLORIDA

CAD FILE:	WATER
DWN BY:	REF
DATE:	30 APR 07
SHEET NO:	25 OF 27
DETAIL	
W-25	