



WATER SERVICE DETAIL

- NOTE:**
1. ALL FITTINGS SHALL BE NO-LEAD BRASS.
 2. ALL WATER METERS SHALL HAVE A DUAL CHECK VALVE.

REV	DATE	BY	REVISIONS
4	14 MAR 17	SEP	REVISED DETAIL & NOTES
3	05 AUG 13	REFJHS	REVISED PER CITY COMMENTS
2	25 MAR 13	REFJHS	ADDED TEXT AT METER BOX
1	03 JUN 11	REFJHS	REVISED DETAIL AND ADDED NOTES

TECHNICAL STANDARDS MANUAL

WATER SERVICE DETAIL

TECHNICAL STANDARDS MANUAL

CITY OF LYNN HAVEN FLORIDA

CAD FILE:	WATER
DWN BY:	REF
DATE:	30 APR 07
SHEET NO:	3 OF 27
DETAIL	W-3

© CITY OF LYNN HAVEN ALL RIGHTS RESERVED. NO PART OF THIS DOCUMENT MAY BE REPRODUCED OR UTILIZED IN ANY FORM WITHOUT PRIOR WRITTEN AUTHORIZATION OF THE CITY OF LYNN HAVEN