



▲ THIS DIMENSION SHALL BE EQUAL TO THE DEPTH OF THE WET WELL OR AS REQUIRED TO MAINTAIN A 5 FOOT (MIN.) BUFFER, WHICH EVER IS GREATER.

- NOTES:
1. REFER TO PLANS FOR SITE-SPECIFIC CONFIGURATION.
  2. PROVIDE PUMP AROUND MANHOLE WITHIN 50 FEET OF WETWELL.
  3. MINIMUM CLEAR DISTANCE OF 3-1/2' SHALL BE PROVIDED IN FRONT OF THE CONTROL PANEL. (NFPA 70 110.26(A)WORKING SPACE).

## PUMP STATION SITE PLAN

NOT TO SCALE

DATE: APR 30, 2007, 1:44:00 PM USER: JEH PROJECT: P:\2007\2007-04-30\2007-04-30.dwg

© CITY OF LYNN HAVEN ALL RIGHTS RESERVED. NO PART OF THIS DOCUMENT MAY BE REPRODUCED OR UTILIZED IN ANY FORM WITHOUT PRIOR WRITTEN AUTHORIZATION OF THE CITY OF LYNN HAVEN



**TECHNICAL  
STANDARDS  
MANUAL**

**PUMP STATION  
SITE PLAN**  
TECHNICAL STANDARDS MANUAL  
CITY OF LYNN HAVEN FLORIDA

CAD FILE:	PSSP
DWN BY:	JEH
DATE:	30 APR 07
SHEET NO:	5 OF 6
DETAIL	
LS-5	