



NOTES:

1. ALL FITTINGS SHALL BE BRASS WITH COMPRESSION/PACK JOINT TYPE CONNECTIONS.
2. ALL TUBING TO BE 200 PSI.
3. ALL CURB STOPS SHALL BE LOCKABLE TYPE FORD GRIP SEAL.
4. ALL CORPORATION STOPS SHALL BE FORD GRIP SEAL.
5. PROVIDE INSERTS AT ALL CORPORATION AND CURB STOPS.
6. PROVIDE #14AWG LOCATOR WIRE ALONG ENTIRE LENGTH OF TUBING.
7. NO SERVICE LINE SHALL TERMINATE UNDER A DRIVEWAY.
8. EACH SERVICE SHALL TERMINATE AT A CURB STOP WHICH SHALL BE BURIED APPROXIMATELY 3" BELOW FINAL GRADE AND SHALL BE CLEARLY MARKED WITH A 2" X 2" X 18" STAKE WITH THE TOP PAINTED BLUE AND MARKED WITH THE NUMBER OF THE LOT TO BE SERVED AND TYPE OF SERVICE PROVIDED, i.e., POTABLE WATER OR RECLAIMED WATER.

WATER & REUSE SERVICE CONNECTION DETAILS

© CITY OF LYNN HAVEN ALL RIGHTS RESERVED. NO PART OF THIS DOCUMENT MAY BE REPRODUCED OR UTILIZED IN ANY FORM WITHOUT PRIOR WRITTEN AUTHORIZATION OF THE CITY OF LYNN HAVEN



TECHNICAL
STANDARDS
MANUAL

WATER AND REUSE
SERVICE CONNECTION DETAILS
TECHNICAL STANDARDS MANUAL
CITY OF LYNN HAVEN FLORIDA

CAD FILE:	WARSCD
DWN BY:	JEH
DATE:	30 APR 07
SHEET NO:	4 OF 26
DETAIL	
W-4	