



**NOTES:**

1. ABOVE DETAIL IS BASED ON 2" COMBINATION AIR/VACUUM RELEASE VALVE. CHANGE PIPE AND FITTINGS ACCORDINGLY FOR OTHER VALVE SIZES AND TYPES. VALVE SIZES TO BE DETERMINED BY THE ENGINEER AND APPROVED BY THE CITY.
2. THE MINIMUM DIMENSION FROM TOP OF PIPE TO FINISHED GRADE SHALL BE 4.0 FEET.
3. ALL VALVE & MH COVERS TO BE PAINTED WITH EXPOXY PAINT. WATERMAIN (BLUE), FORCEMAIN (GREEN), FIREWATER (RED) AND RE-USE (PURPLE)

AIR AND/OR VACUUM RELEASE VALVE DETAIL  
NOT TO SCALE

REV	DATE	BY	REVISIONS
1	17 JULY 05	RAL	ADDED TURN DOWN



**TECHNICAL STANDARDS MANUAL**

**AIR AND/OR VACUUM  
RELEASE VALVE DETAIL  
TECHNICAL STANDARDS MANUAL  
CITY OF LYNN HAVEN FLORIDA**

CAD FILE:	REUSE
DWN BY:	REF
DATE:	30 APR 07
SHEET NO:	11 OF 18
DETAIL	R-11